

SUPPLEMENTARY REPORT ON THE SEEPAGE AT GAOL

The sample of water from the seepage was analysed and found to contain 4.76 grains per gallon of total solids.

This content is very low, and rather suggests that the water is derived from a water pipe. It is quite possible, however, that it is a very good quality underground water with a very short underground course.

The analysis has not definitely decided the origin of the water, and the only procedure to control the seepage is that outlined in the previous report.

P. B. Nye
GOVERNMENT GEOLOGIST

Mines Department,
Hobart.

March 14th, 1927